		PCRS	PCRS	PCRS	EnviroMed	PCRS	PCRS	PCRS	EnviroMed	PCRS	EnviroMed
Location	**Type**	**2/21**	**2/26**	**2/27**	**3/3**	**3/3**	**3/4**	**3/5**	**3/5**	**3/6**	**3/6**
AM Baseline	Outdoor				615	615	478**	464**	446	425	379
200 Hall	Common								829		717
2nd Grd Vestibule	Common		894	758			1613	850		851	
300 Boys Lav	Common								725		1003
300 Girls Lav	Common								732		848
300 Hallway Staff Lav	Common								1039		1225
300 Hall	Common		538	680	1269	618			978		812
400 Boys Lav	Common							1107	1068	797	825
400 Girls Lav	Common							1116	1076	803	747
Art Room	Office	574			1103	1125	949	1178	1381	1047	1260
Assistant Principal	Office				1164			662	683	565	691
ASO	Office								958		627
Cafeteria	Common		679	813	1318	612	903	661	943	936	1024
Conference Room	Office										586
Computer Lab	Classroom				1086				624		645
Food Service Manager	Office				1307			860	795	695	698
Gym	Common		674	705	982	521	624	779	715	580	793
Gym Boiler	Office		489	482		484	501	1096		453	
Hall (Art)	Common	449				681	1025	1780		786	
Hall 211-213	Common					609	233	783		557	
Hall 303-304	Common						618	824		812	
Hall 412-413	Common		617	608		610	1165	992		794	
Hall 419-420	Common		662	613		608	957	1065		787	
Hallway	Common	551					639	783	932	775	617
Hallway by Gym	Common								757		553
Janitorial Office	Office		701	790	789	553	551	585	614	485	547
Kitchen	Common				979				622		901
Library Conference Room	Office				966				852		655

Main Office Conference Room	Common		789	760	850	602	704	665	750	569	
Main Office	Common	420			1037	782	703	788	658	587	552
Main Office Kitchen	Common				1013				520		556
Media Center	Common				875				838		710
Media Center Office	Office				972				1014		636
Music Room	Classroom				1470			1348	1230	1104	1238
Nurse's office	Classroom	362	722	596	775	613	599	617	781	643	584
OTPT	Office				964				762		512
Padded Room	Office				1097			758	1018	743	850
Principal's Office	Office				950			630	636	538	560
Resource	Office				1054				778		530
Room 202	Classroom	540			1029	856	922	1673	1112	809	747
Room 204	Office	589			887	747	559	711	837	626	509
Room 207	Office	497			767	598	526	591	691	552	548
Room 209	Classroom	430	573	596	830	687	968	891	1095	954	912
Room 211	Classroom	429	773	1095	730	681	778	758	834	569	783
Room 213	Classroom	576			744	570	781	776	837	526	620
Room 216	Classroom	540			773	689	757	870	868	495	554
Room 302	Classroom	445			1022	610	672	690	1005	980	593
Room 303	Office	440			1061	619	427	669	778	455	474
Room 304	Office	447			1011	689	518	718	729	708	628
Room 305	Classroom	445			986	596	589*	719	848	846	859
Room 307	Classroom	423	1127	687	1010	753	705	944	919	945	975
Room 309	Office	430			872	566	537	659	760	585	521
Room 310	Office	422			758	553	638	765	784	647	459
Room 311	Classroom				1307			913	935	1230	707
Room 312	Classroom				1041			942	1040	908	1104
Room 313	Classroom	432			948	660	763*	687	838	742	1186
Room 316	Classroom	436		1083*	1078	796	912	1169	1346	1111	1025
Room 317	Classroom	426		675	963	688	736	932	745	834	772
Room 320	Classroom	442			594	567	482*	691	659	800	772
Room 321	Classroom	423	769	675	646	618	863	695	642	718	823

Room 402	Classroom	479			1076	582	802	832	783	768	681
Room 403	Classroom	470			1141	647	1374	942	953	528	646
Room 406	Classroom	428			1144	773	1236	1547	1584	1213	1189
Room 407	Classroom	429	1044	676*	1119	774	1176	1256	1299	920	763
Room 410	Classroom	462			1067	740	1138	1238	1281	1171	950
Room 411	Classroom	469			960	700	710*	1142	1113	856	917
Room 412	Classroom	412			1214	688	478	1790	1765	1001	974
Room 413	Office	454			1014	797	696	974	958	645	658
Room 414	Office	434			1103	649	700	822	828	889	802
Room 416	Classroom	437			1143	825	826	1610	1673	1357	516
Room 417	Classroom	436				607	747	891	850	752	596
Room 418	Classroom				920						
Room 419	Office				1027			917	886	618	456
Room 420	Office	431				617	718	867	803	420	593
Room 421	Classroom	458			1080	646	561	800	728	704	470
Room 519	Office				780			874	839	530	673
Social Worker's Office	Office				1019			973	1004	788	773
Staff Lounge	Common				850			793	715	784	564
Swing Room	Office				943				908		520
The Nest	Office								1353		573

*Window open at time of testing

Occupied during testing

Reduced occupancy during testing

Unoccupied

Occupancy not documented

**Outdoor baseline is an average of three readings